

ADDENDUM NO. 1

**PROJECT: Hickory Hills Snowmaking Electrical Pedestals**

**PROPOSALS DUE: Monday, August 27, 2018, at 1:00 PM**

This addendum is issued prior to the receipt of proposals to amend the proposal as follows:

On page 2 of the bid proposal, the pedestal product detail specification number changed from HBL560R5W to HBL460R5W. The revised paragraph now reads as follows:

PRODUCTS:

1. PEDESTALS

- a. Products: Subject to compliance with requirements, provide the following:  
Twenty Two (22) Electrical Pedestal, 480V at 18 KAIC, 60 AMP, 500MCM Lug with Hubbell HBL460R5W Plug Socket. The electrical pedestal shall accommodate a 3 foot bury depth and a 4 foot above ground height.

All other conditions of this Request for Proposals remain the same.

Bidders must acknowledge receipt of this addendum. Acknowledgement must be shown in the spaces provided herein and must be received with the bid, **Monday, August 27, 2018, at 1:00 PM**, local time, at the place of bid opening at the **Office of the City Manager, Second floor, Governmental Center, 400 Boardman Avenue, Traverse City, Michigan, 49684.**

FAILURE TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WILL CAUSE REJECTION OF BID.

Sincerely,



Timothy J. Lodge, P.E.  
City Engineer

Dated: \_\_\_\_\_

ACKNOWLEDGED:

Bidder: \_\_\_\_\_  
By: \_\_\_\_\_  
Title: \_\_\_\_\_