

---

# Information

**OFFICE OF THE FIRE MARSHAL**

The City of Traverse City  
Fire Department



Station 01, 500 West Front Street, Traverse City MI 49684  
(231) 922-4930 ext. 3

---

## **TOURIST HOME INSPECTION ITEMS**

**Below is a list of items the Fire department is looking for when performing an inspection of a Tourist home:**

**ARE THERE ADDRESS NUMBERS ON THE BUILDING?**

**ARE THERE EGRESS WINDOWS EACH GUEST ROOM?**

**ARE THE EGRESS WINDOWS SIZE IN COMPLIANCE WITH THE MICHIGAN RESIDENTIAL CODE?**

**IS AN EMERGENCY ESCAPE PLAN POSTED IN EACH GUESTROOM?**

**ARE THERE SMOKE ALARMS IN EACH GUEST ROOM?**

**ARE THERE SMOKE ALARMS IN EACH BEDROOM AND ON EVERY LEVEL OF THE HOUSE?**

**WHAT IS THE SMOKE ALARMS POWER SOURCE? AND IF THEY ARE BATTERY POWERED, HAVE THE BATTERIES BEEN CHANGED WITHIN LAST YEAR?**

**IS THE SMOKE ALARM DATE OF MANUFACTURE WITHIN THE LAST TEN YEARS?**

**IS THERE A CARBON MONOXIDE DETECTOR IN THE BUILDING?**

**IS THERE AT LEAST ONE ABC PORTABLE FIRE EXTINGUISHER, MINIMUM SIZE OF 2:a10:bc? AND IS IT ACCESSIBLE AND SECURED?**

**IS PORTABLE FIRE EXTINGUISHER BRAND NEW, AND IF NOT, HAS IT BEEN SERVICED WITHIN LAST YEAR?**

**If you have any questions about these items, please contact the Fire Marshal at 231-922-4930, ext. 3.**